



GOVERNMENT OF KERALA
CERTIFICATE OF EXAMINATION

RAL/TR/PVT


WA(P) No A.16238/B/23-24

Food Safety Department,
Regional Analytical Laboratory,
Ernakulam
Dated : 06/06/2023

Description of sample : KWA Water
Sample Details : Sample received in Plastic Can + Sterile Bottle
Source : Isabella De Rosis Public School, Thevarkad, Varapuzha,
Ernakulam -683 517
Date of Receipt : 26/05/2023
Date of Analysis : Started on 27/05/2023 and completed 03/06/2023
Sample quantity : 2 L + 125 ml
Physical Appearance : Clear, Colourless liquid having agreeable odour.

Sl No.	Test Parameters used	Test Methods	Result of analysis	Desirable limit prescribed standard as per IS No.10500:1991,2012
1	Iron	Qualitative Inorganic Analysis by Vogel	Below Limit of Quantification	0.3 mg/l
2	Ammonia	Is: 3025 Part -34	Nil	0.5 mg/l
3	Coliforms	IS 1622 1981 RA 2019	<2 MPN/100 ml	<2 MPN/100 ml
4	E.Coli	IS 1622 1981 RA 2019	Absent/100 ml	Shall be absent

Limit of Quantification for Iron =0.1 mg/l



Seal

FOOD ANALYST

The test report relates to the test items only. No enquires will be entertained after one month issuing test report. Reproduction of test report in part or full without permission is prohibited. The complete reports includes both A& B.