



Office of The Assistant Executive Engineer.

Local Infra Structure Development & Engineering , Sub Division Alangad .

Ernakulam. 683511.. E-mail : aeelsgdalangad@gmail.com

No. SF.02/AEE/LSGD/ABP /2025

FITNESS CERTIFICATE FOR SCHOOL BUILDINGS

1. Name of Officer : Smt.ANU.T., Assistant Executive Engineer,
LSGD Sub Division, Alangad BP
2. Name of School : ISABELLA DE ROSIS PUBLIC SCHOOL FOR ISABELLA
DE ROSIS CONVENT AT VARAPPUZHA , 683517

3. Location with name of Education District, Sub-District : Varappuzha -Ernakulam -

4. Classification of buildings as specified in column 4 of application for Fitness Certificate and Size : Permanent

Ground floor

Number of Class rooms- 3Nos (8.00 X 6.00 X 3.00 m)

Number of Class rooms- 2Nos (6.00 X 6.00 X 3.00 m)

First floor

Number of Class rooms- 3Nos (8.00 X 6.00 X 3.00 m)

Number of Class rooms- 2Nos (6.00 X 6.00 X 3.00 m)

Second floor


Number of Class rooms- 3Nos (8.00 X 6.00 X 3.00 m)

Number of Class rooms- 2Nos (6.00 X 6.00 X 3.00 m)

5. Period for which the certificate is issued : 2025-26
6. Nature of defect if any
 - a) Foundation and basement : Nil
 - b) Superstructure : Nil
 - c) Doors and Windows : Nil
 - d) Wood work wrought & put up : Nil
 - e) Roof : Nil
 - f) Flooring : Nil
 - g) Miscellaneous (Cracks etc.) : Nil
7. Any major defects noticed which will render the building unsafe in any manner : No
8. Whether the maintenance works have been properly :NA (New construction)
9. . Whether the structure is sound or not for conducting classes : Yes, under normal weather condition

Certified that the school was inspected by me on 15.07.2025 and found to be fit to conduct classes for the period 2025-26 for the reasons stated above.

Place: Alangad
Date: 17.07.2025



Signature: ANU. T.
Designation: 701830
ASSISTANT EXECUTIVE ENGINEER
LID & EW SUB DIVISION
BLOCK PANCHAYATH, ALANGAD

FITNESS CERTIFICATE FOR SCHOOL BUILDING FOR 2025-26

1. Name of Officer : Indushree I.B
2. Name of School : Isabella De Rosis Public School
3. Location with name of Ednl Distr : Chirakkakam (Thevarkad) , Aluva
Educational District
4. Classification of buildings :

Single Storeyed Building

Ground Floor - 7 x 6.00 x 6.00 x 3.40 m R.C.C Roof - 7 Class rooms

1 x 9.00 x 6.00 x 3.40 m R.C.C Roof - 1 Chemistry Lab

1 x 9.00 x 6.00 x 3.40 m R.C.C Roof - 1 Composite Lab

1 x 6.00 x 6.00 x 3.40 m R.C.C Roof - 1 Staff Room

First Floor - 10 x 6.00 x 6.00 x 3.40 m R.C.C Roof - 10 Class rooms

1 x 6.00 x 6.00 x 3.40 m R.C.C Roof - 1 Digital Class rooms

Ground Floor - 4 x 8.00 x 6.00 x 3.40 m R.C.C Roof - 4 Class rooms

1 x 8.00 x 6.00 x 3.40 m R.C.C Roof - 1 Staff Room

1 x 3.00 x 6.00 x 3.40 m R.C.C Roof - 1 Principal Room

1 x 8.00 x 6.00 x 3.40 m R.C.C Roof - 1 Office Room

First Floor - 5 x 8.00 x 6.00 x 3.40 m R.C.C Roof - 5 Class rooms

1 x 8.00 x 6.00 x 3.40 m R.C.C Roof - 1 Digital Class Room

1 x 3.00 x 6.00 x 3.40 m R.C.C Roof - 1 Counselling Room

Second Floor - 5 x 8.00 x 6.00 x 3.40 m R.C.C Roof - 5 Class rooms

1 x 8.00 x 6.00 x 3.40 m R.C.C Roof - 1 Maths Lab

1 x 3.00 x 6.00 x 3.40 m R.C.C Roof - 1 Activity Room

5. Period for which the certificate is issued : 2025-26 Academic Year